WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72260
Permit No. 69
Basin

NOTICE OF INTENT NO. 36087

1. OWNER Dave Rowe
MAILING ADDRESS 5900 E. Feedlot Rd. Dutch Flat
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
Feedlot Rd., Winca NV

2. LOCATION E1/2 1/4 SE 1/4 Sec. 27 T 38N N/S R 38E E Humboldt County
PERMIT NO. _____ Issued by Water Resources
Parcel No. 6-321-24
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	8	8
Cobbles & boulders		8	83	75
Basalt		83	194	111
Clay		194	296	102
Clay w/sand stringers		296	363	67
Cobbles	x	363	406	43

RECEIVED 98 JUN 1 AM 9:57 STATE ENGINEER'S OFFICE

Date started 6/3/98, 19__
Date completed 6/8/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 406 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8	Inches	0 Feet	406 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	400

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 x 3
From 260 feet to 400 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 406 feet

9. WATER LEVEL
Static water level 136 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 6-10-98