WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
VD-98-3

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.348

OFFICE USE ONLY
Log No. 72266
Permit No.
Basin 61

NOTICE OF INTENT NO. 39140

1. OWNER Barrick Goldstrike Mine
MAILING ADDRESS PO Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION
Barrick Goldstrike Mine

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 36 N/S R. 50 E. Eureka County
PERMIT NO. 55141 (Issued by Water Resources) | n/a (Parcel No.) | n/a (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal (Industrial) [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Almvium		0	260	260
Carlin formation		260	330	70
Black Clay/Rock		330	490	160
Gray Clay/Rock		490	530	40
Black Rock		530	570	40
Gray Rock		570	610	40
Almvium formation		610	760	150
Black Clay		760	770	10
Gray Rock/Clay		770	835	65
Brown Rock		835	850	15
Black Rock		850	890	40

RECEIVED 98 MAY -8 AM 0:35 STATE ENGINEERS OFFICE

Date started 4-17, 1998
Date completed 4-23, 1998

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3	174'	1 HR

8. WELL CONSTRUCTION
Depth Drilled 890 Feet Depth Cased 880 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
17.500 Inches	0 Feet	36 Feet
9.875 Inches	36 Feet	890 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3.375	52.06	.375	0	36
6.625	17.00	.250	+2	880

Perforations:
Type perforation Louvered Roscoe Moss
Size perforation .125
From 60 feet to 880 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50' feet to 890' feet

9. WATER LEVEL
Static water level 639.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address 2286 W. 1500 S. (Contractor)
Salt Lake City, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2085

Signed Dan Kohlman (By driller performing actual drilling on site or contractor)
Date 4.23.98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627