WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72271
Permit No.
Basin 92A

NOTICE OF INTENT NO. 37876

1. OWNER HOWARD ASHMORE
MAILING ADDRESS 10224 Danube Drive
Cupertino, California 95014

ADDRESS AT WELL LOCATION 15025 Red Rock Road
Reno, Nevada 89506

2. LOCATION SW ¼ SW ¼ Sec. 17 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-390-03 (Parcel No.) Red Rock Estates #1 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	55	54
Gray sandy clay		55	73	18
Green sandy clay		73	138	65
Gray sandy clay		138	179	41
Green sandy clay		179	255	76
Soft zone (app 2 GPM)	X	255	256	1
Green sandy clay		256	330	74
Soft zone (app 2 GPM)	X	330	331	1
Green sandy clay		331	340	9
Gray sandy clay		340	355	15
Soft zone	X	355	370	15
Gray sandy clay		370	400	30

Date started 7-29-98, 19
Date completed 7-30-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	400 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	400

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 237 feet to 257 feet
From 317 feet to 337 feet
From 377 feet to 397 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 112 feet below land surface
Artesian flow G.P.M. 12 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 3, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627