WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72272
Permit No.
Basin 92A

NOTICE OF INTENT NO. 37875

1. OWNER DENISE SCIONTI
MAILING ADDRESS 7780 Big River Drive
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
15065 Red Rock Road
Reno, Nevada 89506

2. LOCATION NW ¼ NE ¼ Sec. 18 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. Issued by Water Resources | 079-372-03 Parcel No. | Red Rock Estates #25 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clays		1	18	17
Cemented sands & gravels		18	21	3
BRown sandy clay		21	69	48
Green sandy clays		69	101	32
Brown sandy clays		101	161	60
Soft zone, cemented sand & gravel	X	161	180	19
Brown sandy clay		180	201	21
Soft zone, sand & gravels	X	201	215	14
Brown sandy clay		215	234	19
Soft zone, sand & gravels	X	234	241	7
Gray sandy clay		241	250	9

Date started 7-27-98, 19
Date completed 7-29-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	250	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	250

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 180 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 151 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources 923 the on-site driller

Signed [signature] By driller performing actual drilling on site or contractor
Date August 3, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627