WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72274
Permit No.
Basin 105

NOTICE OF INTENT NO. 37589

1. OWNER Ed Apple
MAILING ADDRESS P.O. Box 926
Gardnerville nev 89410

ADDRESS AT WELL LOCATION 2440 Richards Ct.
Gardnerville nev 89410

2. LOCATION SE ¼ NW ¼ Sec. 4 T. 12 N/S R. 21 E. Douglas County

PERMIT NO. ____ Issued by Water Resources | Parcel No. 35-150-33 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy, Lome, Top Soil		0	7	7
gravel	yes	7	30	23
Sandy clay		30	42	12
gravel	yes	42	70	38
brown clay		70	85	15
gravel	yes	85	107	22
Hard clay + Small Rock		107	125	18
Gravel + coarse Sand Some Small Clay Seams	yes	125	180	55

RECEIVED 98 JUL 22 AM 9:18 STATE ENGINEER'S OFFICE

Date started July 13, 1998
Date completed July 18, 1998

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	15	3

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	50
6	50	180

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	180

Perforations:
Type perforation Factory Saw Slot
Size perforation 3/32 X 3
From 140 feet to 180 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 8 FT. feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Contractor
Address P.O. Box 92, Smith, nev 89430 Contractor

Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date 7-20-98

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627