WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72285
Permit No.
Basin 59

NOTICE OF INTENT NO. 38548

1. OWNER Echo Bay Minerals
MAILING ADDRESS P.O. Box 1658
Battle Mtn., NV 89820

ADDRESS AT WELL LOCATION Echo Bay Mine Site

2. LOCATION NE ¼ SW ¼ Sec 36 T. 39 N/S R. 42 E. Lander County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Sand Stone Conglomerate		0	400	400

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 3/4 Inches	0 Feet	20 Feet
6 Inches	20 Feet	400 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	20
2		Sch. 80	12	400

Perforations:
Type perforation Slot
Size perforation .060
From 400 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 400 feet to 200 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Chris Schaal (Schaal Drilling)
Address (Contractor) P.O. 2748 Elko NV
Nevada contractor's license number issued by the State Contractor's Board 009378
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2159
Signed (By driller performing actual drilling on site or contractor)
Date 6-21-95

Date started 6-20, 1995
Date completed 6-21, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627