

OFFICE USE ONLY
 Log No. 72289
 Permit No. 212
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17565

1. OWNER American Pacific Corp ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3770 HOWARD HUGHES PKWAY # 366 NW NV 89107 STREET RIGHT-OF-WAY
 2. LOCATION NE 1/4 NW 1/4 Sec 1 T. 22 N. S. R. 62 E County _____
 PERMIT NO. 414 037 3365 Parcel No. MLW K1 Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|--------------|-------------|-------------|------------|
| <u>SANDY GRAVEL</u> | | <u>0</u> | <u>1.5</u> | <u>1.5</u> |
| <u>Brn poorly graded sand and silty clay</u> | | <u>1.5</u> | <u>6.0</u> | <u>4.5</u> |
| <u>Brown clayey sand moist & medium dense</u> | | <u>6.0</u> | <u>12.5</u> | |
| <u>H2O ENCOUNTERED</u> | | <u>12.5</u> | | |
| <u>Brn poorly graded sand w/ clay</u> | | <u>12.5</u> | | |
| <u>gravel</u> | | <u>17</u> | <u>21</u> | |
| <u>white calcareous w/ cemented and hard</u> | | <u>21</u> | <u>23.5</u> | |

8. WELL CONSTRUCTION
 Depth Drilled 23.5 Feet Depth Cased 23.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
6 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-------------|
| <u>2</u> | | <u>sch 40</u> | <u>0</u> | <u>23.5</u> |

Perforations:
 Type perforation machine slotted
 Size perforation .020
 From 6.5 feet to 23.5 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 6' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 6' feet to 23.5 feet

9. WATER LEVEL
 Static water level: 10.0 feet below land surface
 Artesian flow: N/A G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 2-23, 1998
 Date completed 2-23, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |
| | | |
| | | |
| | | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Geo technical & Env. Services Contractor
 Address 7560 W. Sahara Contractor
Las Vegas NV 89117
 Nevada contractor's license number issued by the State Contractor's Board Engineer
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 2-23-98