

OFFICE USE ONLY
 Log No. 72290
 Permit No. _____
 Basin. 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12570

1. OWNER American Pacific Corp ADDRESS AT WELL LOCATION City of Henderson
 MAILING ADDRESS 3770 Howard Hughes Pkwy Street Right of Way
366 N.V. N.V. 89107

2. LOCATION NE 1/4 SE 1/4 Sec. 36 T 21 N(S)R 62 E CLARK County
 PERMIT NO. 161-36-701-001 Parcel No. _____ Subdivision Name MU R-5

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>poorly graded sand w/silt</u>		<u>0</u>	<u>3.5</u>	
<u>pg gravel w/clay and sand</u>		<u>3.5</u>	<u>8.0</u>	
<u>DK brn pg gravel w/clay and sand</u>		<u>8</u>	<u>13</u>	
<u>pg sand</u>		<u>13</u>	<u>13</u>	
<u>∇ H₂O Encountered</u>		<u>22</u>		
<u>DK reddish brown clayey sand</u>		<u>22</u>	<u>38</u>	
<u>white & green mottled lean clay</u>		<u>38</u>	<u>43.5</u>	

8. WELL CONSTRUCTION
 Depth Drilled 43.5 Feet Depth Cased 43.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 43.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>sch 40</u>	<u>0</u>	<u>43.5</u>

Perforations:
 Type perforation machine slotted
 Size perforation ØØ
 From 28.5 feet to 43.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 20-26
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 26 feet to 43.5 feet

9. WATER LEVEL
 Static water level 15.7 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

Date started 4-2 1998
 Date completed 4-2 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Geotechnical & Enviro Services Contractor
 Address 7560 W. Sahara Contractor
Las Vegas, Nev 89117
 Nevada contractor's license number _____ issued by the State Contractor's Board Engineer
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4-2-98