

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16593

1. OWNER American Pacific Corp ADDRESS AT WELL LOCATION City of Henderson
 MAILING ADDRESS 3770 Howard Hughes Pkwy # 366 NV NV 89107 57 feet Right of way
 2. LOCATION N.E. 1/4 NW 1/4 Sec. 15 T 21 N3R 62 E Clark County
 PERMIT NO. 178-15-111-017 Parcel No. _____ Subdivision Name NW-1

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	1	
Brn pg sand w/ sorted gravel & cobbles		1	3	
Brn well graded gravel w/ sand & cobbles		3	11.5	
Brn well graded sand w/ clay & gravel dense Hard clay nodules		11.5	31	
lt brn hard clay - layers & reddish brn sand layers gravel		31	40	
WATER encountered <input checked="" type="checkbox"/>			49	
dk brn clay gravel			55	

8. WELL CONSTRUCTION
 Depth Drilled 55 Feet Depth Cased 55 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 Inches To 0 Feet 55 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>sch 40</u>	<u>0</u>	<u>55</u>

 Perforations:
 Type perforation mechanically slotted
 Size perforation 020
 From 30 feet to 35 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 24 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 27 feet to 55 feet

Date started 11/18, 1997
 Date completed 11/18, 1997

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 41 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Geotechnical Env. Services Contractor
 Address 7560 W. Sahara Las Vegas Nev 89117 Contractor
 Nevada contractor's license number issued by the State Contractor's Board Enquest
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11-18-97