WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72295
Permit No.
Basin 212

NOTICE OF INTENT NO. 17566

1. OWNER American Pacific corp
MAILING ADDRESS 3770 Howard Hughes Pkwy #366 LV NV 89107

ADDRESS AT WELL LOCATION City of Henderson 67 feet Right-of-way

2. LOCATION NE ¼ SE ¼ Sec. 10 T. 22 N/S R. 62 E. Clark County
PERMIT NO. Issued by Water Resources | 183-149-286 Parcel No. | Subdivision Name mu-F

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brn poorly graded gravel w/sand, cobbles and boulders		0	4	
LT/Brn dry gravel w/silt sand cobble		4	16	
Dk brn cemented sand & gravel, cemented and Hard to very Hard		16	18	
Dk brn dry gravel & sand cobbles and boulder		18	21	
Dk brn cemented sand & gravel		21	33	
Red brn sandy lean clay w/gravel		33	43	
water encountered		43		
LT Brn clayey sandy gravel		43	60	
Brn poorly graded gravel w/clay & sand		60	63	

AUG 10 1998

Date started 9-6, 1997
Date completed 9-6, 1997

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 63 Feet Depth Cased 63 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 Inches	0 Feet	63 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40	0	63

Perforations:
Type perforation machine slotted
Size perforation .020
From 30 feet to 63 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 25 feet to 63 feet

9. WATER LEVEL
Static water level 43 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Geotechnical & Envi. Services (Contractor)
Address 7560 W. Sahara (Contractor)
Las Vegas Nev. 89117
Nevada contractor's license number issued by the State Contractor's Board Engineer
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
Signed (By driller performing actual drilling on site or contractor)
Date 9-6-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627