WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72298
Permit No.
Basin 212

NOTICE OF INTENT NO. 17580

1. OWNER American Pacific corp
MAILING ADDRESS 3770 Howard Hughes Pkwy #366 L.V. NV. 89107

ADDRESS AT WELL LOCATION City of Henderson street of Right of-way

2. LOCATION SE ¼ NW ¼ Sec. 11 T. 22 N/S R. 62 E. Clark County
PERMIT NO. 178-11-601-001 (Issued by Water Resources) | Parcel No. | Subdivision Name MW-AG

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pale Brown pg graded gravel w/ sand cobbles & Boulder		0	6	
more Boulders		6	17	
light brn dry		17	24	
cemented		24	28	
Brn pg sand		28	30	
Pale brn cemented sand gravel		30	33	
Light brn silty		33	40	
cemented		40	53	
▽		53		
Light brn sandy lean clay		53.5	68	
caliche		68	81	
partially cemented		81	97	
cemented		97	102	
▽		102		
gravel		108	121	
pale reddish brown clayey sand		121	123	

Date started 2-16, 1998
Date completed, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 123 Feet Depth Cased 123 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	5/8 Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		.020	0	102
		sch 40		

Perforations:
Type perforation machine slotted
Size perforation .020
From 102 feet to 123 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 82
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 98 feet to 123 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Geotechnical + Env. Services (Contractor)
Address 7560 W. Sahara (Contractor)
Las Vegas Nev. 89117
Nevada contractor's license number issued by the State Contractor's Board Engineer
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
Signed [signature] By driller performing actual drilling on site or contractor
Date 2-16-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627