WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72302
Permit No.
Basin 230

NOTICE OF INTENT NO. 17773

1. OWNER James Baker
MAILING ADDRESS P.O. Box 146, Amargosa Valley, NV 89020
ADDRESS AT WELL LOCATION Quarterhorse + Powerline

2. LOCATION NE ¼ NE ¼ Sec. 7 T. 17 N/S R. 49 E. Nye County
PERMIT NO. (Issued by Water Resources) APN 19-401-43 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvial		0	60	60
Sandstone		60	80	20
Limestone		80	90	10
Sand + small gravel	1st	90	115	25
Bed of Clay		115	130	15
Bed of Clay + gravel		130	140	10
Sand & gravel	2nd	140	157	17
Sandy Clay		157	160	3
Bottom of Hole				

RECEIVED 98 JUN -9 PM 12:08 STATE ENGINEERS OFFICE

JUL 24 1998

Date started May 18, 1998
Date completed May 20, 1998

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10¼ Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" P.V.C.			0	160

Surface protective casing
6' of 8" Steel casing .1808 wall

Perforations:
Type perforation Machined
Size perforation 3" x 1/8" every 12"
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60' feet to 160 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 70 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling (Contractor)
Address HC 69 Box 452 (Contractor)
Amargosa Valley, NV 89020
Nevada contractor's license number issued by the State Contractor's Board 5376 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 830
Signed Dave Ray
By driller performing actual drilling on site or contractor
Date 5-25-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627