WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72314
Permit No.
Basin 212

NOTICE OF INTENT NO. 18594

1. OWNER American Pacific Corp
MAILING ADDRESS 3770 Howard Hughes Pkwy #366 LV NV 89107

ADDRESS AT WELL LOCATION City of Henderson street Right-of-way

2. LOCATION SW ¼ SW ¼ Sec. 10 T. 22 N/S R. 62 E. Clark County
PERMIT NO. (Issued by Water Resources) 176-10-499-001 (Parcel No.) Subdivision Name MW-L

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt lt brn pg sand		0	1	
Lt brn pg gravel w/sand cobbles + boulders		1	13	
Fewer cobbles & boulders			26	
pg sand & clay		26	36	
partially cemented		36	37.5	
Reddish brn pg sand w/clay cemented		37.5	81	
▽		80		
pg gravel w/sand cemented & dense		81	86.5	

Date started 11/20, 1997
Date completed 11/20, 1997

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 86.5 Feet Depth Cased 86.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 5/8 Inches	0 Feet	86.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		sch 40	0	86.5

Perforations:
Type perforation machine slotted
Size perforation 020
From 51 feet to 86.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 49
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 52.5 feet to 86.5 feet

9. WATER LEVEL
Static water level 59.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Geotechnical & Env. Services Inc (Contractor)
Address 7560 W. Sahara Las Vegas Nev 89117 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board Exempt Engineer
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
Signed (By driller performing actual drilling on site or contractor)
Date 11-20-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627