

OFFICE USE ONLY
 Log No. 72341
 Permit No. 105
 Date 8-20-98

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39792

1. OWNER Ron Ficklen ADDRESS AT WELL LOCATION 1736 Toni Court
 MAILING ADDRESS 1736 Toni Court Minden, Nevada
 2. LOCATION NW 1/4 SE 1/4 Sec 2 T 13 N R 20 East Douglas County
 PERMIT NO. 23-510-40 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand & multi colored gravels		0	6	6
brown sand w/brown clay		6	20	14
multi colored gravels & coarse sand		20	30	10
weathered granite fractured		30	35	5
multi colored gravels w/brown clay		35	110	75
multi colored gravels w/course sand		110	170	60
brown clay w/multi colored gravels		170	250	80
multi colored coarse sand and gravels		250	260	10
multi colored coarse sand & gravels w/gray clay		260	300	40
gray clay w/multi colored gravels		300	320	20
multi colored coarse sands & gravels	X	320	360	40
T.D. 360				

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 360 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 360 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	17.0	.225	+1-1/2	360

Perforations:
 Type perforation factory
 Size perforation 3/32 x 3
 From 320 feet to 340 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 360 feet to 50 feet

9. WATER LEVEL
 Static water level 225 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality _____

Date started 8-14-98, 19____
 Date completed 8-18-98, 19____

7. WELL TEST DATA

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>4 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc Contractor
 Address P.O. Box 60130 Contractor
Reno, Nevada 89506
 Nevada contractor's license number issued by the State Contractor's Board 0035387-A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
 Signed Randy Litch
 By driller performing actual drilling on site or contractor
 Date 8-20-98