

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 72349  
Permit No. 84  
Basin 84  
NOTICE OF INTENT NO 38304

1. OWNER **Richard Williamson**  
MAILING ADDRESS **1285 Baring Blvd #308 Sparks, NV**

ADDRESS AT WELL LOCATION **Bacon Rind Rd**

2. Location **NW 1/4 NW 1/4 Sec 6 T 21N R 21E Washoe County**  
PERMIT NO. \_\_\_\_\_ PARCEL NO. **076-190-02** SUBDIVISION NAME \_\_\_\_\_

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE  
 New Well | Replace | Recondition |  Domestic | Irrigation | Test | Cable |  Rotary | RVC  
 Deepen | Abandon | Other | Municipal/Industrial | Monitor | Stock | Air | Other |  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine sands & gravel.		0	43	43
Coarse tan yellow brown white DG sands & gravels.		43	158	115
Yellow white granite fracture with occasional tan clay layer		158	205	47
Green white granite.		205	280	75

8. WELL CONSTRUCTION  
 Depth Drilled 280 feet | Depth Cased 280 feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 feet To 175 feet | 10 5/8 inches  
 From 175 feet To 280 feet | 8 3/4 inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	280

Perforations::  
 Type Perforation **Factory**  
 Size perforation **3/32 x 3"**  
 From **280** feet to **260** feet  
 From **240** feet to **220** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal  YES No  
 Depth of Seal **58** feet  
 Pumped \_\_\_\_\_  
 Poured  Concrete Grout  
 Gravel Packed:  Yes No  
 From **280** feet to **58** feet

RECEIVED  
 90 AUG 14 AM 11:28  
 STATE ENGINEERS OFFICE

Date started **7-13 -98**  
 Date completed **7-17 -98**

9. WATER LEVEL  
 Static water level **125** feet below land surface  
 Artesian flow **0** GPM **0** P.S.I.  
 Water Temperature **cold** Degrees F Quality \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)		
<b>35</b>	<b>142</b>	<b>1</b>		
<b>45</b>	<b>192</b>	<b>2 1/2</b>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**  
 NV Contractors No. **14170**  
 NV Driller's Lic (on site) **1511**  
 Signed Stan McKay  
 By driller performing actual drilling on site or contractor  
 Date **7-29-98**