

OFFICE USE ONLY  
 Log No. 72355  
 Permit No. \_\_\_\_\_  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17944

1. OWNER JOHN DJURIC ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 SW 1/4 Sec. 16 T. 23 N. R. 61 E. CLARK County  
 PERMIT NO. 191-16-301-002 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, CLAY & ROCK		0	5	5
SANDY CLAY		5	60	55
CEMENTED GRAVEL		60	425	365
RED SANDSTONE	X	425	500	75
CEMENTED GRAVEL	X	500	535	35
RED SANDSTONE	X	535	560	25
CEMENTED GRAVEL	X	560	625	65

8. WELL CONSTRUCTION  
 Depth Drilled 625 Feet Depth Cased 625 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 625 Feet  
9 3/4 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	PVC	SDR 21	0	625
6 5/8	12.9	.188	+2	8

Perforations:  
 Type perforation FACTORY  
 Size perforation 1/8 X 3 4 ROWS  
 From 545 feet to 565 feet  
 From 585 feet to 605 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 625 feet

9. WATER LEVEL  
 Static water level 362 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8/4 19 98  
 Date completed 8/7 19 98

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WATER WELL SERVICES Contractor  
 Address 6475 GARY AVE. Contractor  
LAS VEGAS, NV 89139  
 Nevada contractor's license number issued by the State Contractor's Board 22311B  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 8/21/98

