

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 12398
 Permit No. _____
 Basin 72

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37989

1. OWNER Stanley Monroe ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 365 970 Pacific Avenue
Imlay, NV 89418 Imlay, NV 89418

2. LOCATION 1/4 1/4 Sec. 8 T 32 N/S R 34 E Pershing County
 PERMIT NO. 6-103-03 Noble Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	6	6
Sand & Gravel		6	19	13
Blue Clay		19	89	70
Sand & Gravel		89	106	17

8. WELL CONSTRUCTION

Depth Drilled 106 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>10 7/8</u> Inches	<u>0</u> Feet	<u>106</u> Feet	<u>106</u> Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet

Division of Water Resources
 We contacted the Pershing County Assessor's office & they informed us that they have no 1/4 sections for Parcel No. 6-103-03. They advised that you might request a deed from the Recorder's office if you would like further information.
 Sincerely,
 Humboldt Drilling

CASING SCHEDULE

Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>.188</u>	<u>+1</u>	<u>100</u>
_____	_____	_____
_____	_____	_____

row mill slot

_____ feet to <u>100</u> feet
_____ feet to _____ feet
_____ feet to _____ feet
_____ feet to _____ feet
_____ feet to _____ feet

Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

No Seal
 _____ feet to 106 feet

RECEIVED
 28 AUG - 5
 STATE ENGINE

Date started 7/6/98, 19____
 Date completed 7/8/98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>8</u>	<u>3</u>	<u>3</u>
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 66 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 8-4-98