

Faxed - 8-14-98

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. **72413**
Permit No. **162**
Basin **162**



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **17309**

1. OWNER Rick Pasco ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Blagg Street _____
 2. LOCATION SE 1/4 NE 1/4 Sec. 28 T. 19S. R. 53E. Nye County _____
 PERMIT NO. 88-891-31 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Soil		0	7	7
Brown Clay		7	22	15
Caliche		22	25	3
Brown Clay	X	25	80	55
Red Lime	X	80	82	2
Grey Clay	X	82	90	8
Gravel	X	90	91	1
Grey Clay	X	91	106	15
Gravel	X	106	109	3
Grey Clay	X	109	117	8
Gravel	X	117	120	3
Brown Clay	X	120	180	60

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Inches To 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	0	177	0	180

Perforations:
 Type perforation Factory Saw
 Size perforation _____
 From _____ feet to _____ feet
 From 120 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 56 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Palmump Water Well Service Contractor
 Address P.O. Box 3392
Palmump, Nevada 89011
 Nevada contractor's license number 0035900
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
 Signed Kenny Jenkins
 By driller performing actual drilling on site or contractor
 Date 8-4-98

Date started 7-31-98, 19_____
 Date completed 8-4-98, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>3</u>	<u>1/2</u>

