

dated 8-14-98

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 72417  
Permit No. 162  
Basin 162

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17303

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

1. OWNER Al Settles  
MAILING ADDRESS Pahrump  
ADDRESS AT WELL LOCATION Linda Street Pahrump  
2. LOCATION SW 1/4 SW 1/4 Sec 16 T. 20 N. R. 53E Nye County  
PERMIT NO. 35-331-60 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	2	2
Grey Clay		2	20	18
Brown Clay	X	20	96	76
Caliche	X	96	98	2
Brown Clay	X	98	140	42

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet  
HOLE DIAMETER (BIT SIZE)  
From 12 Inches To 0 Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12</u>	<u>0</u>	<u>.177</u>	<u>0</u>	<u>140</u>

Perforations:  
Type perforation Factory  
Size perforation 5/8"  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 120 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 140 feet

9. WATER LEVEL  
Static water level: 53 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.  
Water temperature Cold °F Quality good

Date started 7-22-98, 19\_\_\_\_\_  
Date completed 7-26-98, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>3</u>	<u>1 1/2</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Pahrump Water Well Service Contractor  
Address P.O. Box 3392 Contractor  
Pahrump, NV 89011  
Nevada contractor's license number issued by the State Contractor's Board: 0035901  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1916  
Signed Harry Jenkins  
By driller performing actual drilling on site or contractor  
Date 7-26-98

