WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72441
Permit No.
Basin 212

NOTICE OF INTENT NO. 1820T

1. OWNER Ryder Truck Rental
MAILING ADDRESS 3600 NW 82ND Avenue Miami, Florida 33166-6623
ADDRESS AT WELL LOCATION 4530 South Polaris Avenue Las Vegas, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 20 T. 21 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 162-203-02001 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty SAND and Gravel		0	.5	
dry, tan to brown, silty				
Fine to coarse sand				
and subangular to				
subrounded gravel				
gravelly silty sand /		.5	7	
sandy silt, dry to				
slightly moist, tan to				
white, angular to				
subangular gravel in				
fine to coarse sand & silt				
Caliche, dry, some		7	12	
moist areas, white to tan				
Clay, moist, white to tan		12	16	
Sandy gravelly silt, wet		16	20	
white to tan, fine to				
coarse sand and angular				
to subrounded gravel in silt				
gravelly sandy clay,		20	30	
wet, reddish brown,				
angular to subrounded				
gravel in fine to				
coarse sandy plastic				
clay				
Gravelly sandy silt,		30	33	
wet, tan to white				
angular to subrounded				
gravel in fine to coarse				
sandy silt some				
plastic clay				

Date started 8.13.1998
Date completed 8.13.1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED SEP 11 1998 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 10 Feet

HOLE DIAMETER (BIT SIZE)
6 Inches From 0 Feet To 33 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"			0	10

Perforations:
Type perforation Sch 40
Size perforation .020
From 10 feet to 33 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 33 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name The Verde Companies, Inc. Contractor
Address 301 West Dell Valley Road #7 Contractor
Dell Valley, Arizona 85027
Nevada contractor's license number issued by the State Contractor's Board 41809
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2070
Signed [signature]
By driller performing actual drilling on site or contractor
Date August 31, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627