WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72468
Permit No.
Basin 212

NOTICE OF INTENT NO. 16563

1. OWNER Tab
MAILING ADDRESS 3614 N 5th St NLV NV
ADDRESS AT WELL LOCATION Off Lellis @ Sahara

2. LOCATION NE ¼ NE ¼ Sec. 8 T. 21 N/S R 62 E Clark County
PERMIT NO. DW 1092 (Issued by Water Resources) 161-08-501-005 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Bucket

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fine sand | | 0 | 16 | 16 |
| sand & gravel | | 16 | 26 | 10 |
| sandy chys | | 26 | 36 | 10 |
| sand w/ gravel | | 36 | 40 | 4 |

Date started 8-7, 1998
Date completed 8-7, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)
24 Inches From 0 Feet To 40 Feet
____ Inches ____ Feet ____ Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | Sch 40 | PVC | 0 | 40 |

Perforations:
Type perforation slot
Size perforation .003
From 10 feet to 40 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature 001 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GDC Contractor
Address 536 E Maitland Contractor
Ontario CA
Nevada contractor's license number issued by the State Contractor's Board 31246
Nevada driller's license number issued by the Division of Water Resources, the on site driller M-1985
Signed [signature]
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627