WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72486
Permit No.
Basin 108

NOTICE OF INTENT NO. 37588

1. OWNER Rick Otto
MAILING ADDRESS Tibbals Rd. Hwy 208 Yerington, Nev 89447
ADDRESS AT WELL LOCATION Tibbals Rd Hwy 208 Yerington, Nev 89447

2. LOCATION SW ¼ SW ¼ Sec. 26 T. 12 N/S R. 25 E Lyon County
PERMIT NO. (Issued by Water Resources) Portion of 12-37-12 (Parcel No.) None (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Adobe top Soil		0	12	12
Coarse gravel	yes	12	30	18
Cobble stones	yes	30	42	12
gravel coarse Sand + Some fine Sand	yes	42	100	78

RECEIVED 98 AUG 13 AM 11:3 STATE ENGINEER'S OFFICE

Date started Aug 3, 19 98
Date completed Aug 10, 19 98

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	57+	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 Inches		50 Feet	120 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~~188~~				
6 5/8		188	0	120

Perforations:
Type perforation Factory saw slot
Size perforation 3 32x3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller (Contractor)
Address P.O. Box 92 (Contractor)
Smith, Nev 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date Aug 10, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627