


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 72500  
 Permit No. \_\_\_\_\_  
 Basin 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18056

1. OWNER Rudy Tapia ADDRESS AT WELL LOCATION 171 E. Stagecoach  
 MAILING ADDRESS 171 E. Stagecoach 171 E. Stagecoach  
Pahrump, NV 89048

2. LOCATION NW 1/4 SW 1/4 Sec. 3 T 20S N/S R 53E E Nye County  
 PERMIT NO. 35-521-02 Nye County  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown sandy loam and gravel		0	2	2
brown sandy loam		2	12	10
brown calache		12	18	6
brown sandy loam		18	40	22
brown loam and gravel		40	55	15
brown loam and gravel	x	55	65	10
brown loam and calache	x	65	69	4
grey calache	x	69	80	11
brown calache	x	80	100	20
brown calache	x	100	125	25
See next line	x	125	140	15
brown loam/strings brown calache				

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation saw cut  
 Size perforation .188

From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 9-28-98

Date started 9/9/98 . 19  
 Date completed 9/9/98 . 19

7. WELL TEST DATA

TEST METHOD: G.P.M.	TEST METHOD:	
	<input type="checkbox"/> Bailer Draw Down (Feet Below Static)	<input type="checkbox"/> Pump Time (Hours)
<u>.5</u>	<u>na</u>	<u>.50</u>

SEP 28 1998