WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72504
Permit No.
Basin 162

NOTICE OF INTENT NO. 16924

1. OWNER Edgar & LuAnn Rothe
MAILING ADDRESS 5555 Ute Hwy
Longmont, CO 80503

ADDRESS AT WELL LOCATION
3270 Gally
Pahrump, NV 89048

2. LOCATION SW ¼ SW ¼ Sec. 25 T 19S N/S R 52 E Nye County
PERMIT NO. 28-256-06 (Issued by Water Resources) | 28-256-06 (Parcel No.) | Bell Vista U5/6 B-C L20 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Grey Clay		4	16	12
Brown Clay		16	48	32
Grey Clay		48	63	15
White Clay	X	63	78	15
Brown Clay	X	78	110	32
Lite brown clay	x	110	142	32
White clay	X	142	160	18

SEP 25 1998

Date started Sept 9, 1998
Date completed Srpt 10, 1998

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	-0-	15 min

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17#	.188	0	160

Perforations:
Type perforation Torch cut
Size perforation ½ wide x 8" long
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg Well Drilling (Contractor)
Address 1060 W. Basin Rd., Pahrump, NV (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 7484 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg by CSD (By driller performing actual drilling on-site or contractor)
Date Sept 21, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627