WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 74525
Permit No. 60165
Basin 212

NOTICE OF INTENT NO. 17953

1. OWNER DESERT INN HOTEL
MAILING ADDRESS 3139 LAS VEGAS BLVD. SO.
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NE ¼ Sec. 16 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. 60165 (Issued by Water Resources) 162-16-601-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	8	8
CALICHE		8	35	27
GRAVEL & CLAY	X	35	60	25
CALICHE		60	70	10
CLAY & GRAVEL	X	70	230	160
SAND & GRAVEL	X	230	275	45
SANDY CLAY		275	290	15
SAND & GRAVEL	X	290	320	30
CLAY		320	345	25
SAND & GRAVEL	X	345	375	30
SANDY CLAY & GRAVEL	X	375	390	15
SAND & GRAVEL	X	390	445	55
CLAY		445	500	55

Date started 9/2, 19 98
Date completed 9/21, 19 98

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches		0 Feet	50 Feet
14 3/4 Inches		50 Feet	500 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18	47.4	.250	0	50
8 5/8	22.36	.250	+2	500

Perforations:
Type perforation FACTORY
Size perforation .100 X 3 24 ROWS
From 240 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 195
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 195 feet to 500 feet

9. WATER LEVEL
Static water level 118 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WATER WELL SERVICES (Contractor)
Address 6475 GARY AVE. (Contractor)
LAS VEGAS, NV 89139
Nevada contractor's license number issued by the State Contractor's Board 22311B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1963
Signed (By driller performing actual drilling on site or contractor)
Date 9/24/98

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627