WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72552
Permit No.
Basin 162

NOTICE OF INTENT NO. 16928

1. OWNER Ronald R. Jacobus
MAILING ADDRESS 651 W. McMurray
Pahrump, NV 89048

ADDRESS AT WELL LOCATION 651 W. McMurray
Pahrump, NV 89048

2. LOCATION SE ¼ NW ¼ Sec. 28 T. 19S N/S R. 53 E Nye County
PERMIT NO. 29-902-12 (Issued by Water Resources) | 29-902-12 (Parcel No.) | Bell Vista Unit 3, Block 7, Lot 12 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Soft Sandy clay		4	24	20
Hard clay		24	32	8
Soft lite colored clay		32	93	61
Sand and gravel	x	93	101	8
Cemented gravel		101	108	7
Hard pan		108	116	8
Brown clay	x	116	144	28
Hardpan		144	150	6
Brown Clay	x	150	160	10

OCT 2 1998

Date started Sept 24, 2998, 19
Date completed Sept 25, 1998, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	-0-	15 min

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	160 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17#	.188	0	160

Perforations:
Type perforation Torch cut
Size perforation ¾" wide x 8" long
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 72 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg Well Drilling (Contractor)
Address 1060 W. Basin Rd. (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg by EEO
By driller performing actual drilling on site or contractor
Date Sept 28, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627