

STATE OF NEVADA
 DIVISION OF WATER RESOURCES



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17748

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Lacey Perry ADDRESS AT WELL LOCATION 5671 Sunland
 MAILING ADDRESS 5671 Sunland
Pahrump, NV 89048

2. LOCATION NW 1/4 SW 1/4 Sec. 8 T 21S N/S R 54E E Nye County
 PERMIT NO. 45-101-24 Issued by Water Resources Parcel No. Nye County Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown sandy loam</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>brown clay</u>		<u>12</u>	<u>35</u>	<u>23</u>
<u>brown clay</u>		<u>35</u>	<u>53</u>	<u>18</u>
<u>brown clay</u>	<u>x</u>	<u>53</u>	<u>71</u>	<u>18</u>
<u>brown calache</u>	<u>x</u>	<u>71</u>	<u>81</u>	<u>10</u>
<u>light brown calache</u>	<u>x</u>	<u>81</u>	<u>104</u>	<u>23</u>
<u>light brown calache</u>	<u>x</u>	<u>104</u>	<u>120</u>	<u>16</u>
<u>brown clay</u>	<u>x</u>	<u>120</u>	<u>140</u>	<u>20</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 140 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation saw cut
 Size perforation .188

From 110 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 9/29/98 19__
 Date completed 9/29/98 19__

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>.5</u>	<u>na</u>	<u>.50</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed Lacey Strickland
 By driller performing actual drilling on-site or contractor

Date 10/6/98

