WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72596
Permit No.
Basin 203

NOTICE OF INTENT NO. 13796

1. OWNER Art Taylor
MAILING ADDRESS #4 Pam Road Caliente NV 89008

ADDRESS AT WELL LOCATION 1/4 mile North on Pam Road North of Beaver Dam Road By Caliente NV

2. LOCATION S/W 1/4 N/E 1/4 Sec. 14 T. 3 N/S R. 67 E. Lincoln County
PERMIT NO. ____ Issued by Water Resources | 13-170-14 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP Soil		0	12	12
Sand-Gravel		12	48	36
Clay-Boulders		48	65	17
Clay		65	73	8
Boulders-clay	X	73	104	31
Clay		104	111	7
Clay-Boulders	X	111	140	29
Clay		140	146	6
gravel-clay	X	146	155	9
Clay		155	158	3

Date started 9-17-98, 19
Date completed 9-18-98, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
24	7	4

8. WELL CONSTRUCTION
Depth Drilled 158 Feet Depth Cased 158 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	158 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	158

Perforations:
Type perforation Factory
Size perforation 1/8" x 3"
From 98 feet to 118 feet
From 138 feet to 158 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 158 feet

9. WATER LEVEL
Static water level 71 feet below land surface
Artesian flow 0 G.P.M. 0 P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address P.O. Box 54 (Contractor)
Hiko NV 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 9-18-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627