mw-2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

FOR OFFICE USE ONLY
Log No. 72629
Permit No.
Basin 212

NOTICE OF INTENT NO. 17581

1. OWNER American Pacific Corp
MAILING ADDRESS 3770 Howard Hughes Pkwy #366 LV NV 89107

ADDRESS AT WELL LOCATION Street Right-of-way

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 22 N/S R. 62 E County
PERMIT NO. (Issued by Water Resources) 178-02-399-013 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dk brn & gravel w/ clay & sand		0	4.5	
dk brn w/ sand minor silt & gravel some qtz & red andesite		4.5	9.0	
dk brn s moist, minor cementation chips more fine grained		9.0	14.0	
very moist		14	21	
dk brn cem stg cem. hard		21	23	
water ▽ encountered		23'		
dk brn w/ gravel w/ sand v. moist gravel mostly sub angular, isolated cobbles		23'	33'	
		SEP	8	

Date started 2/6, 1998
Date completed 2/6, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 33 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 5/8 Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH 40	0	33

Perforations:
Type perforation machine slotted
Size perforation .020
From 13 feet to 33 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 11 feet to 33 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 70 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Geotechnical & Env. Services (Contractor)
Address 7560 W. Sahara 89117 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board Engineer
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2/6/98

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627