well "P"

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72632
Permit No.
Basin 212

NOTICE OF INTENT NO. 16584

1. OWNER American Pacific Corp.
MAILING ADDRESS 3770 Howard Hughes Pkwy #300 LV NV 89107
ADDRESS AT WELL LOCATION Street Right of way

2. LOCATION NW ¼ SW ¼ Sec. 1 T. 22 N/S R. 62 E County
PERMIT NO. (Issued by Water Resources) Parcel No. 178-01-399-006 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
well graded sand w/gravel		0	2'	
sand w/silt & fine gravel		2'	8'	
brn pp gravel w/silt coarse gravel		8'	16'	
dk brn cem sand		16'	22'	
Hard brn sandy lean clay water Encountered		22	23	
moist stiff-v stiff		23	31	
▽ water Encountered		31		
sand w clay		31	34	
green sandy lean clay v. moist-wet firm		34	36	
red brn pp sand w/clay v. moist		36		

Date started Dec 23, 1997
Date completed, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA	Total	

8. WELL CONSTRUCTION
Depth Drilled 38 Feet Depth Cased 38 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8	0	38

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH 40	0	38

Perforations:
Type perforation machine slotted
Size perforation .020
From 16 feet to 36 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-12'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 12 feet to 36 feet

9. WATER LEVEL
Static water level 31.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name G.E.S. inc (Contractor)
Address 7560 W. Sahara (Contractor)

Nevada contractor's license number issued by the State Contractor's Board Engineer
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2044
Signed (By driller performing actual drilling on site or contractor)
Date 2-17-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627