

OFFICE USE ONLY
 Log No. 72707
 Permit No. 207
 Basin. 207
 NOTICE OF INTENT NO. 30862

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Boyd & Rhonda Badders ADDRESS AT WELL LOCATION None
 MAILING ADDRESS P.O. Box 83 Lund NV 89317

2. LOCATION SW 1/4 SE 1/4 Sec 8 T 12 N/S R. 62 E White Pine County
 PERMIT NO. N/A 11-340-08 None
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	
clay gravel conglomerate		2	20	
gravel		20	25	
Clay gravel con.		25	43	
Sandy Clay		43	58	
gravel con.		58	63	
Clay con.		63	75	
gravel con.		75	79	
Clay Conglomerate		79	84	
gravel	water	84	86	2
Sandy Clay		86	90	
gravel	water	90	95	5
Sandy Clay		95	125	
gravel	water	125	130	5
Sandy Clay		130	134	
gravel	water	134	137	3
Sandy clay		137	143	
gravel	water	143	146	3
Sandy Clay		146	150	

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches 0 Feet 50 Feet
 To 8 Inches 50 Feet 150 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>		<u>.188</u>	<u>1</u>	<u>150</u>

Perforations:
 Type perforation mill
 Size perforation 6 x 2.5" x 8 Arm

From 90 feet to 150 feet
 From 90 feet to 150 feet
 From 90 feet to 150 feet
 From 90 feet to 150 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 95 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow None G.P.M. None P.S.I. None
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nathan R. Maynard Contractor
 Address P.O. Box 176 Lund N.V. 89317 Contractor

Date started May 21, 1998
 Date completed August 14, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>70</u>	<u>5</u>	<u>15</u>

Nevada contractor's license number issued by the State Contractor's Board 0022869
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
 Signed Nathan Maynard By driller performing actual drilling on site or contractor
 Date Sept 3-98

RECEIVED
 08 SEP - 8 AM 11 26
 STATE ENGINEERS OFFICE