

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36055

1. OWNER WINGFIELD SPRINGS ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 7755 SPANISH SPRINGS ROAD HEALTH DEPT PERMIT 006194  
SPARKS NEVADA 89436  
 2. LOCATION NW 1/4 SE 1/4 Sec 13 T. 20 N/S R. 20 E WASHOE County \_\_\_\_\_  
 PERMIT NO. W-500 522-080-01 RED HAWK GOLF COURSE-WINGFIELD SPRINGS  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND, BROKEN ROCK		0	45	45
COBBLES, BOULDERS		45	55	10
CLAY, BROKEN ROCK, COBBLES		55	105	50
BROWN STICKY CLAY		105	162	57
ROCK BROWN CLAY		162	175	13
BEDROCK GREY/BROWN		175	188	13
RED/BROWN CLAY		188	238	50
GREY CLAY & SILT		238	260	32
SAND, BLACK BASALT		260	270	10
BLACK, GREY BASALT		270	310	40
CLAY, BROKEN ROCK		310	395	85
BROWN/GREY CLAY		395	419	24
BLACK ROCK, SAND, CLAY		419	498	79
GREY/GREEN CLAY, SAND		498	586	88
WHITE/GREY CLAY		586	640	54
HOLE ABANDON				
18 YARDS <sup>3</sup> WAS PUMPED FROM SURFACE VIA TREMI PIPE FROM THE BOTTOM OF THE HOLE TO THE SURFACE				

8. WELL CONSTRUCTION  
 Depth Drilled 640 Feet Depth Cased NONE Feet  
 HOLE DIAMETER (BIT SIZE)  
12 3/4 Inches From 0 Feet To 640 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
NONE				

 Perforations:  
 Type perforation NONE  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 640  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started JUNE 26, 1998  
 Date completed AUGUST 17, 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality FAIR

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SARGENT IRRIGATION COMPANY Contractor  
 Address 9955 NORTH VIRGINIA STREET Contractor  
RENO NEVADA 89506  
 Nevada contractor's license number issued by the State Contractor's Board 21246  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1789  
 Signed \_\_\_\_\_ By driller performing actual drilling on site or contractor  
 Date AUGUST 19, 1998