WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72714
Permit No.
Basin 207

NOTICE OF INTENT NO. 34806

1. OWNER Dan Holstead
MAILING ADDRESS Rt. 2 Box 21 Ely Nev. 89301
ADDRESS AT WELL LOCATION Holstead Ranch 4 miles North of Lund Nv

2. LOCATION N/W ¼ S/W ¼ Sec. 17 T. 12 N/S R. 62 E White Pine County
PERMIT NO. 55016 (Issued by Water Resources) 013-041-01 (Parcel No.) — (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TOPSoil - Boulders | | 0 | 30 | 30 |
| Sand - Gravel | | 30 | 40 | 10 |
| Boulders - Gravel | | 40 | 60 | 20 |
| Clay - Boulders | | 60 | 92 | 32 |
| Gravel - Clay | X | 92 | 145 | 53 |
| Sand - Gravel | X | 145 | 164 | 19 |
| Clay | | 164 | 169 | 5 |
| Boulders - Clay | + | 169 | 184 | 25 |

RECEIVED 98 AUG 10 AM 11:16 STATE ENGINEER'S OFFICE

Date started 5-18-98, 19
Date completed 6-3-98, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 42 | 1 | 7 |

8. WELL CONSTRUCTION
Depth Drilled 184 Feet Depth Cased 184 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 22 Inches | | 0 Feet | 184 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 12 3/4 | - | .250 | 0 | 184 |
| | | | | |

Perforations:
Type perforation torch cut
Size perforation 1/8" x 6"
From 64 feet to 84 feet
From 104 feet to 144 feet
From 164 feet to 184 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 184 feet

9. WATER LEVEL
Static water level 66 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address P.O. Box 54 Hiko NV 89017 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date

(REV. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627