

OFFICE USE ONLY
 Log No. 72743
 Permit No. _____
 Basin 44

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36951

1. OWNER RICHARD KIDD ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS HC 34-438-10
ELKO, NV 89801
 2. LOCATION S 92 1/4 N 42 1/4 Sec. 22 T. 36 N 57 E ELKO County
 PERMIT NO. 024-010-002 Parcel No. RIVER VALLEY RANCHOS Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	1	1
Clay & sand		1	8	7
Sand & gravel	dry	8	18	10
Sand & gravel	uv	18	51	33
Clay & sand	✓	51	56	5
Clay, sand, gravel	✓	56	60	4
Sand	uv	60	126	66
T.D. 126 Ft.				

8. WELL CONSTRUCTION
 Depth Drilled 126 Feet Depth Cased 126 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
1.0 Inches 0 Feet 49 Feet
6 Inches 49 Feet 126 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>126</u>

Perforations:
 Type perforation Mill slots & Torch cut
 Size perforation 1/8 x 3 & 1/16 x 5
 From _____ feet to _____ feet
 From 80 feet to 92 feet
 From 100 feet to 121 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 18-38 Neat Cement
 Placement Method: Pumped 5-18 Cement Grout
 Poured Concrete Grout
36-50 Bentonite
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 4-25, 1998
 Date completed 5-11, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bail test	<u>20</u>	<u>40</u>	<u>2 hrs.</u>
Pump	<u>15</u>	<u>20</u>	<u>4 hrs.</u>

9. WATER LEVEL
 Static water level 9 feet below land surface
 Artesian flow No G.P.M. _____ P.S.I. _____
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Muth Drilling Co.
 Address 203 Pine Street
Elko, NV 89801
 Nevada contractor's license number issued by the State Contractor's Board 10919
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 652
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date _____