WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72800
Permit No.
Basin 101

NOTICE OF INTENT NO. 36224

1. OWNER KOPAS KONSTRUCTION
MAILING ADDRESS P. O. BOX 5024
FALLON, NV 89406

ADDRESS AT WELL LOCATION
1490 GOLDEN PARKWAY, Fallon

2. LOCATION NE 1/4 SE 1/4 Sec. 24 T 19 N/S R 29 E CHURCHILL County
PERMIT NO. _____ Issued by Water Resources | Parcel No. 8-322-55 | VENTURACCI ESTATES Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	10	10
BR CLAY		10	13	3
BR SAND		13	25	12
GREY SAND		25	50	25
BLK SILT/CLAY		50	70	20
GREY SAND		70	80	10
GREY CLAY		80	84	4
BLACK SILT		84	90	6
GRAVEL		90	100	10
CLAY		100	104	4
B SAND	X	104	112	8

RECEIVED 98 SEP -8 AM 10:31 STATE ENGINEER'S OFFICE

Date started 7/17/98, 19__
Date completed 8/15/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 112 Feet Depth Cased 112 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
103/4	Inches	0	Feet	100	Feet
6 1/4	Inches	100	Feet	112	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	112

Perforations:
Type perforation MACHINE SLOT
Size perforation .088
From 105 feet to 110 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 15.5 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address 305 E. WILLIAMS AVE. P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed _____ (By driller performing actual drilling on-site or contractor)

Date 8-28-98