

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36582

1. OWNER Mark Laren 20 ADDRESS AT WELL LOCATION lot - 7 sheet B  
 MAILING ADDRESS Her - 30 Box 30 145 Sage Lake Drive Elko  
Elko NV  
 2. LOCATION SE 1/4 SW 1/4 Sec 35 T 35 N/S R 56 E Elko County  
 PERMIT NO. 006-310-011 Parcel No. Sage Lake Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material   | Water Strata | From | To  | Thick-ness |
|------------|--------------|------|-----|------------|
| TOP soil   |              | 0    | 2   | 2          |
| Caliche    |              | 2    | 4   | 2          |
| sand       |              | 4    | 69  | 65         |
| sand stone |              | 69   | 129 | 60         |
| water sand | X            | 129  | 150 | 21         |
| Clay       |              | 150  | 155 | 5          |

RECEIVED  
 98 AUG - 6 AM 10:45  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION 155  
 Depth Drilled 155 Feet Depth Cased 155 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 150 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>10</u>          |                     | <u>188</u>              | <u>0</u>    | <u>155</u> |

Perforations:  
 Type perforation Face slot  
 Size perforation 1/8 x 6  
 From 130 feet to 150 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 155 feet

9. WATER LEVEL  
 Static water level 62 feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AAA Drilling Contractor  
 Address P.O. Box 2487 Contractor  
Elko NV  
 Nevada contractor's license number issued by the State Contractor's Board 0020684  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
 Signed Shane Bennett  
 By driller performing actual drilling on site or contractor  
 Date Jan 26 - 98

Date started Jan 26 - 1998  
 Date completed Jan 26 - 1998

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.     | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>30+</u> | <u>0</u>                      | <u>2</u>     |