WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72806
Permit No.
Basin 89

NOTICE OF INTENT NO. 38037

1. OWNER Chuck Nichter
MAILING ADDRESS 1995 Eastlake Blvd
Carson City, NV 89704

ADDRESS AT WELL LOCATION
1995 Eastlake Blvd, Carson City

2. LOCATION NW 1/4 NW 1/4 Sec. 31 T 17N N/S R 20E E Washoe County
PERMIT NO. WaCo#6168 (Issued by Water Resources) 050-368-06 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| See next line | x | 80 | 168 | 88 |
| White & blk decomposed frac granite | | | | |
| Hard Salt & Pepper granite | | 168 | 172 | 4 |

Date started 7/29/98, 19__
Date completed 7/30/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 23 | 10 | 1 hr. |

8. WELL CONSTRUCTION
Depth Drilled 172 Feet Depth Cased 172 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 6 1/8" | Inches | 80 | Feet | 172 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5" | 10.79 | .188 | 52 | 172 |

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 132 feet to 152 feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ___ feet to ___ feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed B. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 8-3-98