WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72809
Permit No.
Basin 83

NOTICE OF INTENT NO. 39079C

1. OWNER Sierra Pacific Power Co.
MAILING ADDRESS P.O. Box 10100
Reno, NV 89520

ADDRESS AT WELL LOCATION South of Tracy Power Plant

2. LOCATION SW 1/4 NE 1/4 Sec. 33 T 20N N/S R 22E E Storey County
PERMIT NO. TW-3 (Issued by Water Resources) M10-381 Parcel No. 04-091-01 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 4" x				
72' monitor well by filling with				
approx. 8 sacks of neat cement				
mixed at 5.2 gal/sack. We				
installed tremie tube and filled				
from bottom to top using pressure				
grout machine.				

RECEIVED 98 JUL 14 AM 9:47 STATE ENGINEER'S OFFICE

Date started 6/9/98, 19__
Date completed 6/9/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 72 Feet Depth Cased 72 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		Sch 40	0	72

Perforations:
Type perforation Factory
Size perforation .020
From 52 feet to 72 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 54.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc.
Contractor
Address 1600 Mt. Rose Hwy
Contractor
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 6-10-98