WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72816
Permit No.
Basin 103

NOTICE OF INTENT NO. 28163

1. OWNER Norm Robinson
MAILING ADDRESS 21 Sandafar Dayton NV.
ADDRESS AT WELL LOCATION 21 Sandafar Dayton NV.

2. LOCATION NW ¼ NW ¼ Sec 7 T 16 N S R 22 E Lyon County
PERMIT NO. (Issued by Water Resources) 0116-311-03 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soft DG Sands		0	15	15
Hard Pack Clay Brown		15	32	17
DG Sands		32	72	40
Course Sands and Small Gravels		72	80	8
Brown Clay Strata		80	120	40
Small Gravels DG Sands W/Clay Seams Fractures in Areas	XXX	120	160	40

RECEIVED 98 MAY -8 PM 12:22 STATE ENGINEERS OFFICE

Date started 4-29, 1998
Date completed 4-30, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	60	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling (Contractor)
Address 20 Kit Kat Dr. (Contractor)
Carson City NV. 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 4-30-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627