WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72817
Permit No.
Basin 103

NOTICE OF INTENT NO. 28164

1. OWNER Norm Robinson
MAILING ADDRESS 21 Sandpiper Dayton NV.
ADDRESS AT WELL LOCATION 21 Sandpiper Dayton NV.

2. LOCATION NW ¼ NW ¼ Sec. 7 T. 16 N/S R. 22 E. Lyon County
PERMIT NO. Issued by Water Resources
Parcel No. 016-311-03
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Set up over				
8" well and started				
to Perforated it.				
and water and Are				
Started to Come up				
Side So we Hook				
on to it with				
Cables and Pulled				
out old Casing				
As we Pulled out.				
Casing Hole was				
Filled with Bentonite				
1/2 Pellets to 10'				
From Top and Cement				
to Surface				

Date started 5/1, 1998
Date completed 5-1, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 87 Feet Depth Cased 87 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 5/8 Inches	0 Feet	87 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
~~14.37~~ 8 5/8	14.37	.188	0	8

Perforations:
Type perforation
Size perforation N/A
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured N/A
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Capital City Well Drilling
Address (Contractor) 20 Kit Kat DR
Carson City NV. 89704
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed (By driller performing actual drilling on site or contractor)
Date 5-1-98

RECEIVED 98 MAY 12 PM 2:22 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627