WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72818
Permit No. 89
Basin

NOTICE OF INTENT NO. 9882

1. OWNER Judy Cerder
MAILING ADDRESS 5440 East Lake Blvd
Washoe Valley NV 89704

ADDRESS AT WELL LOCATION 3260 Clark DR.
~~To be Determined By Washoe Co.~~

2. LOCATION NE ¼ SW ¼ Sec. 6 T. 16 N/S R. 20 E. Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. 50-444-26 | Subdivision Name New Washoe City

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Sands DG Sands		0	47	47
Brown Clay		47	94	47
Gray Silty Sands and Clay		94	136	42
Brown Clay and Obsidian Sands		136	163	27
Coarse DG Sands fractures	xxx	163	180	17

Date started 6-8, 1998
Date completed 6-10, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	40	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation Mill Slot.
Size perforation 3 x 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 65
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 65 feet to 180' feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. 20+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Capital City Well Drilling Contractor
Address 20 Kit Kat DR. Contractor
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Heck By driller performing actual drilling on site or contractor
Date 6-12-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627