

OFFICE USE ONLY  
 Log No. 72823  
 Permit No. \_\_\_\_\_  
 Basin. 89

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37776

1. OWNER Freddy Christison ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2395 Beaver 2395 Beaver  
Carson City, NV 89704 Carson City, NV 89704  
 2. LOCATION SE 1/4 NW 1/4 Sec. 31 T. 17 N. S. R. 20 E. AST WASHOE County  
 PERMIT NO. \_\_\_\_\_  
 Issued by Water Resources 050-388-05 Parcel No. \_\_\_\_\_  
 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine gray & white sand	X	80	125	45
Weathered granite w/gray sand		125	127	2
Weathered granite w/gray clay		127	129	2
Weathered granite		129	132	3
Weathered granite w/gray clay		132	135	3
Green white & black granite - hard		135	147	12
Green, white & black granite fractured		147	155	8
Weathered granite hard		155	167	12
Weathered granite fractured		167	172	5
Black & white granite hard		172	174	2
Black & white granite fractured		174	177	3
Black & white granite hard		177	189	12
Black & white granite w/gray clay		189	190	1
T.D. 190'				

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
6-1/8 Inches 80 Feet 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	6.56	.188	20	190

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 x 3  
 From 1.60 feet to 1.80 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal In place  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service Inc. Contractor  
 Address P.O. Box 60130 Contractor  
Reno, NV 89506  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2066  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-14-98

Date started June 10, 1998  
 Date completed June 17, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>8</u>		<u>8 hours</u>