

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39788

1. OWNER Pat Bergeret ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2290 Rabbit 2290 Rabbit  
Carson City NV 89704  
 2. LOCATION SE  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 37.31 T. 17 N S. R. 20 E AST WASHOE County  
 PERMIT NO. 050-386-08 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Multi colored course sand & gravels		75	80	5
Gray clay w/multi colored course sand		80	90	10
Brown & white clay		90	95	5
Brown clay		95	100	5
Gray clay w/white black gravels		100	120	20
Gray & white clay w/white & black course sand.		120	130	10
Gray clay w/black & white sand stone		130	135	5
Fractured decomposed granite	X	135	153	18
Brown clay with decomposed granite		153	156	3
Decomposed granite fractured		156	170	14
T.D. 170'				

cased with 8" to 80'  
 Fill at 75' drilled to 170' cased with 6-5/8" to 10' below ground level & gravel packed to 25' below ground level.

8. WELL CONSTRUCTION  
 Depth Drilled 170 Feet Depth Cased 170 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 7-7/8 Inches 75 Feet 170 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	170	-10

Perforations:  
 Type perforation Johnson Screen  
 Size perforation .030  
 From 130 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal In place  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 170 feet to 25 feet

9. WATER LEVEL  
 Static water level 25 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

Date started July 22, 19.98  
 Date completed July 24, 19.98

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
15		2 hrs	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service Inc. Contractor  
 Address P.O. Box 60130 Contractor  
Reno, Nv 89506  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-28-98