WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72828
Permit No.
Basin 70

NOTICE OF INTENT NO. 37995

1. OWNER Winnemucca Airport
MAILING ADDRESS Jay's Road
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION
Jay's Road
Winnemucca, NV 89445

2. LOCATION NE 1/4 SW 1/4 Sec. 15 T 35 N/S R 37 E Humboldt County
PERMIT NO. 45650 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	6	6
Clay		6	49	43
Gravel		49	64	15
Clay		64	118	54
Gravel		118	145	27
Clay w/Sand Stringers		145	155	10

Plugged by well log #115054

RECEIVED 98 AUG -6 AM 10:49 STATE ENGINEERS OFFICE

Date started 7-30, 1998
Date completed 7-31, 1998

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+		2

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 7/8	0	155

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	150

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 x 3
From 110 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 155 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2019

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 8-5-98