

OFFICE USE ONLY
 Log No. 72906
 Permit No. 419
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22221

1. OWNER Frank KERR ADDRESS AT WELL LOCATION Block 15
 MAILING ADDRESS HC 34 unit 1 SP 19 Lot 8 K.H. Riggs Canyon
ELKO NV 89802
 2. LOCATION SE 1/4 NE 1/4 Sec. 33 T. 35 N. R. 55 E. ELKO County
 PERMIT NO. 037-015-008 MVR # 5
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP soil		0	2	2
Caliche		2	5	3
Cemented Gravel		5	58	53
Clay		58	153	37
Coarse sand		153	243	110
gravel sand	X	243	271	28
Clay		271	285	14

8. WELL CONSTRUCTION
 Depth Drilled 285 Feet Depth Cased 285 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 285 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>285</u>

Perforations:
 Type perforation Face slot
 Size perforation 1/2 x 6
 From 260 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 285 feet

9. WATER LEVEL
 Static water level 168 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started Apr. 1 3 1998
 Date completed Apr. 1 4 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>← 30</u>	<u>7</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Rockwell Drilling Contractor
 Address P.O. Box 6000 Contractor
ELKO NV 89802
 Nevada contractor's license number issued by the State Contractor's Board 0030630
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
 Signed Alan Bennett
 By driller performing actual drilling on site or contractor
 Date Apr. 1 - 5 - 98

RECEIVED
 98 AUG -6 AM 10:47
 STATE ENGINEERS OFFICE