WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 72916
Permit No.
Basin 129

NOTICE OF INTENT NO. 30417

1. OWNER Nick Jones
MAILING ADDRESS 3100 Unionville Rd
Unionville, NV 89418
ADDRESS AT WELL LOCATION 3100 Unionville Rd

2. LOCATION NW ¼ NW ¼ Sec. 20 T. 30 N R. 34 E. Pershing County
PERMIT NO. Issued by Water Resources
12-03-03 Parcel No.
N/A Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay/Source gravel		10	20	20
Clay/fine gravel		20	30	10
Clay/Rock		30	50	20
Clay/Source gravel		50	60	10
Clay/Rock		60	70	10
Clay/fine gravel		70	80	10
white clay/Source gravel		80	100	20
Clay/Solid Rock		100	120	20
Clay/rock		120	140	20
Bedrock	XX	140	160	20

Date started 5/1, 1996
Date completed 5/5, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	N/A	3 hours

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 7/8 Inches	1 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	188	1	160

Perforations:
Type perforation Factory Cuts
Size perforation 3/32
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 63'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 63' feet to 160 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature 60°F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FRED Anderson
Contractor
Address 10760 Grass Valley
Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 21467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed
By driller performing actual drilling on site or contractor
Date 5/31/96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627