

OFFICE USE ONLY  
 Log No. 72917  
 Permit No. 12  
 Basin 30418

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT

1. OWNER Nick Jones ADDRESS AT WELL LOCATION 4205 UNIONVILLE RD.  
 MAILING ADDRESS 3100 UNIONVILLE RD. UNIONVILLE, NV 89418  
 2. LOCATION NE 1/4 NE 1/4 Sec 27 T 30 S R 34 E SPERSHING County  
 PERMIT NO. 12-02-04 Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
COURSE GRAVEL		0	30	30
SOLID ROCK		30	40	10
COURSE GRAVEL		40	50	10
COURSE CLAY		50	60	10
FINE CLAY		60	70	10
CLAY/FINE GRAVEL		70	80	10
CLAY/ROCK		80	90	10
CLAY/GRAVEL		90	100	10
CLAY/ROCK	XX	100	110	10
BEDROCK	XX	110	120	10

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 120 Feet  
 From 1 Feet To 120 Feet  
 From 1 Feet To 120 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>12</u>	<u>.188</u>	<u>1</u>	<u>120</u>

Perforations:  
 Type perforation FACTORY CUTS  
 Size perforation 3/32  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 70'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 70' feet to 120 feet

9. WATER LEVEL  
 Static water level 20' feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature 60.1 °F Quality GOOD

Date started 4/29 1996  
 Date completed 5/1 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>	<u>N/A</u>	<u>3 hr.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED ANDERSON Contractor  
 Address 10760 GRASS VALLEY WINNEMUCCA, NV 89445 Contractor  
 Nevada contractor's license number 21467 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 5/31/96