

OFFICE USE ONLY
 Log No. 72922
 Permit No. _____
 Basin _____
 71 T
 30260

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30260

1. OWNER Gunn + Vandiest ADDRESS AT WELL LOCATION Blackco Lot 7
 MAILING ADDRESS PO Box 867 Winnemucca, NV 89446
 2. LOCATION NW 1/4 NW 1/4 Sec. 1 T 34 QSR 37 E Pershing County
 PERMIT NO. Domestic Sanoma View Estates Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsail		0	10	10
Clay		10	20	10
Gravel + Clay		20	60	40
Clay		60	80	20
Sand + Gravel	XX	80	100	20

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 100 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>1 88</u>	<u>+1</u>	<u>100</u>

Perforations:
 Type perforation Factory cut
 Size perforation 3/32 x 4
 From 80 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 80 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 22 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 60 °F Quality Good

Date started May 27, 1998
 Date completed May 28, 1998

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Contractor
 Address 10760 Grass Valley Rd Contractor
Winnemucca NV
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed Chris Klend
 By driller performing actual drilling on site or contractor
 Date May 29 - 98