

OFFICE USE ONLY
 Log No. 72923
 Permit No. _____
 Basin. 71
 NOTICE OF INTENT NO. 33451

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Garret VanDiest ADDRESS AT WELL LOCATION Anthony St Winnemucca NV
 MAILING ADDRESS P.O. Box 867 Winnemucca, NV 89446
 2. LOCATION Sec 1/4 SE 1/4 Sec 8 T. 33 N. 38 E Pershing County
 PERMIT NO. Domestic Block 12 Lot A Green Acres
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Topsoil</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Rock + Sand</u>		<u>10</u>	<u>40</u>	<u>30</u>
<u>Gravel + Sand</u>	<u>yes</u>	<u>40</u>	<u>60</u>	<u>20</u>
<u>Clay + Rock</u>		<u>60</u>	<u>100</u>	<u>40</u>
<u>Sand + Gravel</u>	<u>yes</u>	<u>100</u>	<u>140</u>	<u>40</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1.85</u>	<u>11</u>	<u>140</u>

Perforations:
 Type perforation Factory Cut
 Size perforation 3/32 x 4
 From 130 feet to 140 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 140 feet to 50 feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Good

Date started 6-24- 19 98
 Date completed 6-25- 19 98

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling Contractor
 Address 10760 Grass Valley Rd Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-26-98