

REPORT NO. 98.47

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

LOG NO. 72930

PERMIT NO. _____

BASIN _____

NOTICE OF INTEREST NO. 39475

1. OWNER Tom & Linda Eisenhart

ADDRESS OF WELL 2307 Canal Rd

MAILING ADDRESS 2307 Canal Rd Reno, Nv 89511

Reno, Nv 89511

2. WELL LOCATION SW 1/4 NE 1/4 SEC. 23 T 20N R 23 E Storey COUNTY

PERMIT NO R-331 PARCEL NO 004-041-30 SUBDIVISION NAME _____

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Multi-colored rock, red, purple, tan & black		0	66	66
Very hard lite green rock with dark green chips mixed in,		66	129	63
Mostly brown rock with some white & clear chips	X	129	140	11
Medium-hard lite green rock		140	186	46
Red rock		186	193	7
Dark gray & black rock		193	198	5
Lite gray with small black specks		198	207	9
Green rock chips mixed with gray		207	252	45
Green rock mixed with some black		252	261	9
Red-brown rock	X	271	273	2
Lite & dark green rock with some multi-colored, tan, blk, wht, clear		273	340	67

RECEIVED
30 NOV 19 10 58 AM '98
STATE ENGINEERING BOARD

8. WELL CONSTRUCTION

Depth Drilled 340 Depth Cased 340

HOLE DIAMETER (BIT SIZE)

~~10 5/8~~ inches 0 Feet 73 Feet
6 1/8 inches 73 Feet 340 Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+2	73
5	9.69	.188	60	340

PERFORATIONS:

Type Perforation Factory Size Perforation 3/32 x 3
From 260 Feet to 280 Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL: Yes No

Seal Depth 66'

SEAL TYPE:

Neat Cement
 Cement Grout

PLACEMENT METHOD:

Pumped Concrete Grout
 Poured

GRAVEL PACKED:

Yes No

From _____ Feet to _____ Feet

9. WATER LEVEL

Static Water Level 55 Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, Nv 89502

DRILLER'S LIC. NO. _____
NV. CONTRACTOR'S LIC. NO. 15291 ON SITE 1132

Signed Roger M Thull

By driller performing actual drilling on site or contractor

Dated November 10, 1998

7. WELL TEST DATA

TEST METHOD Bailor Pump Air Develop

	GPM	DRAWDOWN	TIME (HRS)
from 180'	20		1

Notes : 3 yards of concrete grout used for sanitary seal

Date Started 10/28/98

Date Completed 11/10/98